

VDE Prüf- und Zertifizierungsinstitut

Zeichengenehmigung / Gutachten mit Fertigungsüberwachung

Name und Sitz des Genehmigungs-Inhabers / Name and registered seat of the Certificate holder

OMRON Corporation Safety Standards Group IAB Global Quality Center, Shiokoji Horikawa, SHIMOGYO-KU, KYOTO 600-8530, JP Japan

Dieses Blatt gilt nur in Verbindung mit Blatt 1 des Zeichengenehmigungsausweises Nr. 6359.
This supplement is only valid in conjunction with page 1 of the Certificate No. 6359

Rubrik / Rubric

341

Aktenzeichen / File ref.

586103-4940-0002/235463/CC1/MIM

Ausweis-Nr. /
Certificate No.
6359

letzte Änderung / updated

2017-05-22

Anlage /
Appendix
100A

Datum / Date

1997-02-03

Elektromechanisches Elementarrelais <i>Electromechanical elementary relay</i>	Typenschlüssel <i>Nomenclature</i>									
Beispiel: <i>Example:</i>	$\frac{LY}{I} - \frac{1}{II} - \frac{F}{III} - \frac{0}{IV} - \frac{ACD}{V} - \frac{QSK1}{VI} - \frac{QSK2}{VII} - \frac{6VDC}{VIII}$									
I Basic series	LY : LY – Relay									
II Number of poles	1 : 1 pole 2 : 2 pole									
III Mounting Construction	Blank : Standard Type F : Top bracket mounting S : Bottom bracket mounting									
IV Terminal Configuration	Blank : Standard soldered terminal 0 : Printed circuit terminal Q : Wrapping terminal									
V Contact Material	Blank : AgSnIn ACD : AgCdO									
VI Optional suffix(es)	May include optional letter(s) and/or number(s) for safety standard(s) or/and additional function testing. Note: before optional suffix(es) can be blank or " - "									
VII Optional suffix(es)	May include optional letter(s) and/or number(s) for sales purpose. Note: before optional suffix(es) can be blank or " - "									
VIII Coil Voltage	DC 6 to 100/110V DC AC 6 to 220/240V AC Note : 1. The detail coil ratings should be stated at the electrical endurance data sheet. 2. The coil ratings may be marked at the next line of the above type series marking on the relay. And also " - " is not marked at the head of it.									
Lot No. eg.) 16 7 4 YU or 16 7 04 YU 16th July. 2004 made by YU date,month (1 to 9 ,X=10,Y=11,Z=12) , tail of year , factory's ID No.	<table border="0"> <tr> <td>VDE's ID</td> <td>Omron's ID</td> <td>Factory's name</td> </tr> <tr> <td>AY</td> <td>YU</td> <td>AMAKUSA IKEDA DENKI Co., Ltd.</td> </tr> <tr> <td>BD</td> <td>H1</td> <td>PT OMRON MANUFACTURING OF INDONESIA</td> </tr> </table>	VDE's ID	Omron's ID	Factory's name	AY	YU	AMAKUSA IKEDA DENKI Co., Ltd.	BD	H1	PT OMRON MANUFACTURING OF INDONESIA
VDE's ID	Omron's ID	Factory's name								
AY	YU	AMAKUSA IKEDA DENKI Co., Ltd.								
BD	H1	PT OMRON MANUFACTURING OF INDONESIA								

